

OFFICE OF THE PRINCIPAL M.L.B. MEDICAL JHANSI

Technical Specification PRICE BID

Item Name - Servo Stabilizer

	<u>Technical Specification</u>		<u>Qty</u>	<u>RATE</u>	<u>GST %</u>	<u>Amount</u>
1	Rating in KVA	250 KVA	01 Nos			
2	type	unbalance				
3	cooling	Oil cooling (with oil)				
4	Input voltage	260 – 460 v (line voltage)				
5	Output voltage	415 V +- 1% (line voltage)				
6	Protection	Over voltage under voltage delay timer				
7	Display	Digital with input and output voltage flas auto				
8	certificate	ISO 9001 certified company manufactured				
9	Efficiency	More than 95%				
10	variance	Copper wound with CRGO lamination				
11	Oil tank	With minimum 12SWG CRCA sheet				
12	Warranty	Two Years				